

## Appendix E - Circuit Breakers: Lecture Room (DB Box One)

Operational test on all RCBOs at least once every three months

Key:

✓ Acceptable

✗ Fault

Date	RCBO	R1 Lecture Room Sockets	Y1 Outside Stations	B1 Radio Obs Sub-Main (Non-RCBO)	R2, Y2, B2 Anti-Surge (Non-RCBO)	R4 Shed	Y4 Projector	B4 Induction Loop	R5, Y5, B5 DB Box 2 (Non-RCBO)	R6 Lecture Room Lighting
	Checked			N/A	N/A				N/A	
Signature	RCBO	Y6 Lecture Room Heating Control	B6 Lecture Room Heaters				Actions Required if any			
	Checked									
Date	RCBO	R1 Lecture Room Sockets	Y1 Outside Stations	B1 Radio Obs Sub-Main (Non-RCBO)	R2, Y2, B2 Anti-Surge (Non-RCBO)	R4 Shed	Y4 Projector	B4 Induction Loop	R5, Y5, B5 DB Box 2 (Non-RCBO)	R6 Lecture Room Lighting
	Checked			N/A	N/A				N/A	
Signature	RCBO	Y6 Lecture Room Heating Control	B6 Lecture Room Heaters				Actions Required if any			
	Checked									
Date	RCBO	R1 Lecture Room Sockets	Y1 Outside Stations	B1 Radio Obs Sub-Main (Non-RCBO)	R2, Y2, B2 Anti-Surge (Non-RCBO)	R4 Shed	Y4 Projector	B4 Induction Loop	R5, Y5, B5 DB Box 2 (Non-RCBO)	R6 Lecture Room Lighting
	Checked			N/A	N/A				N/A	
Signature	RCBO	Y6 Lecture Room Heating Control	B6 Lecture Room Heaters				Actions Required if any			
	Checked									
Date	RCBO	R1 Lecture Room Sockets	Y1 Outside Stations	B1 Radio Obs Sub-Main (Non-RCBO)	R2, Y2, B2 Anti-Surge (Non-RCBO)	R4 Shed	Y4 Projector	B4 Induction Loop	R5, Y5, B5 DB Box 2 (Non-RCBO)	R6 Lecture Room Lighting
	Checked			N/A	N/A				N/A	
Signature	RCBO	Y6 Lecture Room Heating Control	B6 Lecture Room Heaters				Actions Required if any			
	Checked									