

Appendix F - Circuit Breakers: Office (DB Box Two)

Operational test on all RCBOs at least once every three months

Key:

✓ Acceptable

✗ Fault

Date	RCBO	R1 Kitchen Sockets	Y1 Dome & Hall Lighting	B1 Office Computer Switch	R2 Cooker Point	Y2 Telescope Control Panel (Non-RCBO)	B2 Stepper Motor Board	R3 Kitchen Lighting	Y3 Dome Double Sockets	B3 Workshop Sub-Main (Non-RCBO)
	Checked					N/A				N/A
Signature	RCBO	R4 Water Heater on Stairs	Y4 Sockets on Stairs	B4 Office Lighting	R5, Y5, B5 Dome Motors (Non-RCBO)	B6 Office Sockets & Heaters	Actions Required if any			
	Checked				N/A					
Date	RCBO	R1 Kitchen Sockets	Y1 Dome & Hall Lighting	B1 Office Computer Switch	R2 Cooker Point	Y2 Telescope Control Panel (Non-RCBO)	B2 Stepper Motor Board	R3 Kitchen Lighting	Y3 Dome Double Sockets	B3 Workshop Sub-Main (Non-RCBO)
	Checked					N/A				N/A
Signature	RCBO	R4 Water Heater on Stairs	Y4 Sockets on Stairs	B4 Office Lighting	R5, Y5, B5 Dome Motors (Non-RCBO)	B6 Office Sockets & Heaters	Actions Required if any			
	Checked				N/A					
Date	RCBO	R1 Kitchen Sockets	Y1 Dome & Hall Lighting	B1 Office Computer Switch	R2 Cooker Point	Y2 Telescope Control Panel (Non-RCBO)	B2 Stepper Motor Board	R3 Kitchen Lighting	Y3 Dome Double Sockets	B3 Workshop Sub-Main (Non-RCBO)
	Checked					N/A				N/A
Signature	RCBO	R4 Water Heater on Stairs	Y4 Sockets on Stairs	B4 Office Lighting	R5, Y5, B5 Dome Motors (Non-RCBO)	B6 Office Sockets & Heaters	Actions Required if any			
	Checked				N/A					
Date	RCBO	R1 Kitchen Sockets	Y1 Dome & Hall Lighting	B1 Office Computer Switch	R2 Cooker Point	Y2 Telescope Control Panel (Non-RCBO)	B2 Stepper Motor Board	R3 Kitchen Lighting	Y3 Dome Double Sockets	B3 Workshop Sub-Main (Non-RCBO)
	Checked					N/A				N/A
Signature	RCBO	R4 Water Heater on Stairs	Y4 Sockets on Stairs	B4 Office Lighting	R5, Y5, B5 Dome Motors (Non-RCBO)	B6 Office Sockets & Heaters	Actions Required if any			
	Checked				N/A					