

Appendix H - Emergency Lighting

Operational test on all lights at least once a month, 3 hour duration test on all lights at least once a year

Key:

✓ Acceptable

RM Running Man

✗ Fault

Date		Switch Location	Lecture Room		Office		Top of Dome Stairs				Signature	
		Light Location	Lecture Room	Lecture Room Exit (RM)	Office	Kitchen	Bottom of Stairs (RM)	Top of Stairs (RM)	Aperture	Control Panel		
		Checked										
Test Type		Switch Location	Workshop Entrance						Actions Required if any			
Operational		Light Location	Entrance Ramp	Exit Door (RM)	Inner Exit Door (RM)	Optics Store	Toilet	Hallway				
3 Hr Duration		Checked										

Date		Switch Location	Lecture Room		Office		Top of Dome Stairs				Signature	
		Light Location	Lecture Room	Lecture Room Exit (RM)	Office	Kitchen	Bottom of Stairs (RM)	Top of Stairs (RM)	Aperture	Control Panel		
		Checked										
Test Type		Switch Location	Workshop Entrance						Actions Required if any			
Operational		Light Location	Entrance Ramp	Exit Door (RM)	Inner Exit Door (RM)	Optics Store	Toilet	Hallway				
3 Hr Duration		Checked										

Date		Switch Location	Lecture Room		Office		Top of Dome Stairs				Signature	
		Light Location	Lecture Room	Lecture Room Exit (RM)	Office	Kitchen	Bottom of Stairs (RM)	Top of Stairs (RM)	Aperture	Control Panel		
		Checked										
Test Type		Switch Location	Workshop Entrance						Actions Required if any			
Operational		Light Location	Entrance Ramp	Exit Door (RM)	Inner Exit Door (RM)	Optics Store	Toilet	Hallway				
3 Hr Duration		Checked										

Date		Switch Location	Lecture Room		Office		Top of Dome Stairs				Signature	
		Light Location	Lecture Room	Lecture Room Exit (RM)	Office	Kitchen	Bottom of Stairs (RM)	Top of Stairs (RM)	Aperture	Control Panel		
		Checked										
Test Type		Switch Location	Workshop Entrance						Actions Required if any			
Operational		Light Location	Entrance Ramp	Exit Door (RM)	Inner Exit Door (RM)	Optics Store	Toilet	Hallway				
3 Hr Duration		Checked										